

Material Test Report

Client:

Miscellaneous

Project:

Miscellaneous

Date of Issue:

THIS DOCUMENT SHALL NOT BE REPRODUCED EXCEPT IN FULL


Sample Details

Sample ID: Plaster Sand
Field Sample: PS11001
Date Sampled: 29/09/2011
Source: Stockpile
Material: Plaster Sand
Specification: Plaster Sand
Sampling Method: Hand Sampling [AS1141.3.1]
Location:
GPS Easting:
GPS Northing:

Other Test Results

Description	Method	Result	Limits
Clay and Fine Silt (%)	AS 1141.33	18	15 – 35
Moisture Content (%)	AS 1289.2.1.1	4.9	

Particle Size Distribution



Method: AS 1141.11.1

Drying by: Hotplate

Note: Sample Washed

Sieve Size	% Passing	Limits
2.36mm	100	90 – 100
1.18mm	100	70 – 100
600µm	86	60 – 95
300µm	36	20 – 45
150µm	6	0 – 10
75µm	3	0 – 5

Comments

N/A